

Job Name/Location:

Tag #:

Date:

For: File Resubmit

PO No.:

Approval Other

Architect:

GC:

Engr:

Mech:

Rep:

(Company)

(Project Manager)



ARNU243SKA4

Multi V™ Standard Wall Mounted Unit

24,200 Btu/h Indoor Unit



Performance:

Total Cooling Capacity (Btu/h) ¹	24,200
Heating Capacity (Btu/h) ¹	25,600
Max Power Input (W) ²	53
L / M / H Power Input at Factory	
Default (W)	16 / 26 / 39

Rated capacity is certified under AHRI Standard 1230. Ratings are subject to change without notice. Current certified ratings are available at www.ahridirectory.org.

Electrical:

Power Supply (V/Hz/Ø)	208-230/60/1
Rated Amps	0.52

Piping:

Refrigerant	
Liquid Line (in., O.D.)	3/8 Flare
Vapor Line (in., O.D.)	5/8 Flare
Condensate	
Condensate Line (in., I.D.)	5/8
Factory Installed Pump	No

Controls Features:

- Auto changeover (Heat Recovery only)
- Auto operation
- Auto restart
- Dual thermistor control
- Dual setpoint control
- Multiple auxillary heater applications
- Timer (on/off)
- Weekly schedule
- Auto direction/ swing (up/down)
- Fan speed control
- Jet cool (fast cooling)
- Filter life display
- Child lock
- Group control
- Hot start
- Self diagnostics
- External on/off control
- Wi-Fi compatible
- Auto Fan
- Leak Detection

Optional Accessories:

- ☐ Wireless Remote Controller - PQWRHQ0FDB
- ☐ MultiSITE™ CRC1 Controller - PREMTBVC0
- ☐ MultiSITE™ CRC1+ Controller - PREMTBVC1
- ☐ Simple Remote Controller - PREMTC00U
- ☐ Premium Remote Controller - PREMTA000
- ☐ Remote Temperature Button Sensor - ZRTBS01
- ☐ Simple Dry Contact (1 contact, 24 VAC external power) - PDRYCB100
- ☐ Dry Contact for Third Party Thermostat - PDRYCB320
- ☐ Dry Contact for Economizer - PDRYCB400
- ☐ Auxillary Heater Kit - PRARS1

Unit Data:

Refrigerant Type	R410A
Refrigerant Control	EEV
Sound Pressure dB(A) (H/M/L) ³	46 / 41 / 34
Primary Filter Type	Washable
Unit Net Weight (lbs.)	26.9
Unit Shipping Weight (lbs.)	35.3

Fan:

Type	Cross Flow
Quantity	1
Motor/Drive	Brushless Digitally Controlled/Direct
Motor Quantity	1
Air Flow Rate H/M/L (CFM)	537 / 449 / 371

Notes:

1. See Engineering Manual for sensible and latent capacities.
2. Max. power input is rated at maximum setting value.
3. Sound Pressure levels are tested in an anechoic chamber under ISO Standard 3745.
4. All communication cable to be minimum 18 AWG, 2-conductor, twisted, stranded, shielded and must comply with applicable local and national codes. Ensure the communication cable is properly grounded at the main outdoor unit only. Do not ground the outdoor unit to indoor units / heat recovery units communication cable at any other point. Wiring must comply with all applicable local and national codes.
5. Power wiring is field provided and must comply with the applicable local and national codes.
6. This unit comes with a dry nitrogen charge.
7. All capacities are net with a combination ratio between 95 – 105%.
8. Must follow installation instructions in the applicable LG installation manual.



